

QuietMOD Panels: STC Comparison  
**NVLAP INDEPENDENT 3<sup>rd</sup> PARTY TEST RESULTS**

Updated 5/26/2016

LAB	Panel	Test Date	Test Number	31.5Hz	63Hz	125Hz	250Hz	500Hz	1KHz	2KHz	4KHz	8KHz	STC
<b>Hard/Hard Panels: Reflective Both Sides</b>													
RAL	H/H-NS-39	5/2/2006	TL06-158	--	--	36	34	34	41	43	47	--	39
RAL	H/H-49	12/5/2014	TL14-437	21	21	30	37	48	55	58	63	58	49
RAL	H/H-51	12/5/2014	TL14-435	15	16	30	42	49	55	58	63	48	51
RAL	H/H-52	12/5/2014	TL14-433	17	22	31	40	50	55	57	63	63	52
RAL	H/H-54	8/19/2004	TL02-257	--	--	40	46	51	55	58	62	--	54
RAL	H/H-54	12/1/2014	TL14-428	22	14	38	44	50	54	57	63	54	54
RAL	H/H-54*	12/5/2014	TL14-436	15	16	36	46	50	54	58	63	57	54
USG	H/H-55*	2/2/2016	USG 160202	-	19	32	49	56	61	60	62	52	56
RAL	H/H-57	12/3/2009	TL09-355	--	--	43	49	54	58	60	64	--	57

\*Heavier side toward noise source

**NOTE:** STC Tests do not include data for 31.5Hz, 63Hz or 8KHz. We intentionally included data for those frequencies on our most recent tests.