

QuietLine Panels: STC and NRC Comparison

NVLAP INDEPENDENT 3rd PARTY TEST RESULTS

Updated 5/26/2016

LAB	Panel	Test Date	Test Number	31.5Hz	63Hz	125Hz	250Hz	500Hz	1KHz	2KHz	4KHz	8KHz	STC
RAL	V-Stack 33	2/4/2008	TL08-039	--	--	14	20	31	42	40	52	--	33
RAL	V-Stack 33	2/4/2008	TL08-010	--	--	0.89	1.23	1.18	1.08	1.06	0.95	--	1.15
RAL	V-Stack 38	2/4/2008	TL08-37	--	--	22	26	35	45	47	48	--	38
RAL	V-Stack 38	2/4/2008	A08-017	--	--	0.86	1.20	1.17	1.07	1.08	1.02	--	1.15
RAL	SL	5/15/2002	TL02-81	--	--	18	26	35	45	49	52	--	37
RAL	SL	5/15/2002	A02-105	--	--	0.92	1.15	1.22	1.13	1.08	1.04	--	1.15
RAL	V-Stack 42	2/15/2002	TL02-83	--	--	23	31	40	49	56	62	--	42
RAL	V-Stack 42	2/15/2002	A02-108	--	--	0.68	1.06	1.12	1.08	1.03	0.98	--	1.05

NOTE: STC Tests do not include data for 31.5Hz, 63Hz or 8KHz. We intentionally included data for those frequencies on our most recent tests.